


SUITABLE FOR MODEL**SAFETY INSTRUCTION:** 

READ CAREFULLY BEFORE INSTALLING FIXTURE. PLEASE KEEP THIS MANUAL FOR FUTURE USING. Fixtures must be wired in accordance with the National Electrical Code and all applicable local codes. Proper grounding is required for safety.

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.

MAKE CERTAIN POWER OFF BEFORE INSTALLING OR MAINTAINING FIXTURE.

CHECK THAT VOLTAGE IS COMPATIBLE WITH FIXTURE DRIVER, USE APPROVED CONNECTORS FOR ALL ELECTRICAL CONNECTIONS.

WARNING: **RISK OF ELECTRICAL SHOCK**

- Turn off electrical power at fuse or circuit breaker box before wiring fixture to the power supply.
- Turn off the power when you perform any maintenance.
- Verify that supply voltage is correct by comparing it with the luminaire label information.
- Make all electrical and grounded connections in accordance with the National Electrical Code and any applicable local code requirements.
- All wiring connections should be capped with UL approved wire connectors.

CAUTION: **RISK OF INJURY**

- Wear gloves and safety glasses at all times when removing luminaire from carton, installing, servicing or performing maintenance.
- Avoid direct eye exposure to the light source while it is on.
- Account for small parts and destroy packing material, as these may be hazardous to children.

CAUTION: **RISK OF FIRE**


- Keep combustible and other materials that can burn away from luminaire and lamp/lens.
- MIN 90°C SUPPLY CONDUCTORS.

WIRE CONNECTION


Universal voltage driver permits operation at 120V thru 277V or 347/480V, 50 or 60Hz

- a. Connect the voltage supply Line to our AC-L terminal
- b. Connect the voltage Neutral supply to our AC-N terminal
- c. Connect the green/yellow ground lead to the supply ground lead

Wiring Diagram For 120-277V/347V/480V



Wiring Diagram For 120-277V/347V/480V External Occupancy Motion Sensor



Ref#: 20210827

INSTALLATION

ACCESSORY PACK FOR MOTION SENSOR (shipped together)



SENSOR LENS X 1

V-HOOK MOUNT

ACCESSORY PACK (shipped together)




V-HOOK X 2


SAFETY CHAIN X 1

Installation: Using Standard hanging V-Clips and chain


1. Loop the **mounting chain** (by others) around the ceiling or service attachment point.
2. Use an **S or similar connector** to close the loop.
3. Slide the other end of the **mounting chain** through the **V-Clip** provided with the fixture. Install the **V-Clip** into the **two slots** shown above to support the fixture. The distance between ceiling and fixture is 39.3" (1m) at least.



Step 1



Step 2



Step 3