

Project Name	
Product Code	
KU No	
1emo	
)ata	



# **BRIWALL LED WALL PACK**



# PRODUCT DESCRIPTION

The Briwall led wall pack series is constructed from durable die-cast aluminum. Full cut-off design. Lumen ranges from 1800lm to 8000lm. Long-lasting, low maintenance, energy efficient replacements for Metal Halide and High Pressure Sodium lamp sources. Designed for commercial and industrial wall applications.

## FEATURE

DIMENSION

- Cutoff distribution design
- Lumen ranges from 1800lm to 8000lm
- Emergency back up, photocontrol and sensor available

## **E**LECTRICAL SYSTEM

- Input voltage:120-277V
- 50/60Hz
- Power Factor: >0.9
- Total Harmonic Distortion: <20% at full load
- Working Temperature: -40 104°F (-40 40°C)
- 0-10V Dimming Standard

# PERFORMANCE

CRI 70

ССТ

### 4000K, 5000K

**Projected Lifetime** 


L70 -100,000 Hours


### Working Temperature


-40 - 104°F (-40 - 40°C)

### Certifications

- cUL listed
- Suitable for wet locations
- RoHs compliant







# Ordering Information

### Example: BWP-SP401-FT

Name	_ Watts	ССТ	Voltage	- Control	- Distribution	- Finish
BWP	<b>SP</b> - 15W/30W /50W/70W selectable <sup>1</sup>	<b>40</b> - 4000K <b>50</b> - 5000K	<b>1</b> -120-277V	Blank - None PC - Photocontrol MS - PIR Sensor <sup>2</sup>	<b>FT</b> - Forward Throw⁴ <b>WT</b> - Wide Throw⁴	<b>- Blank</b> - Bronze
				EBU- Emergency Battery Backup	9 <sup>3</sup>	

1501 Industrial Way N, Toms River, NJ 08755 ©2019 ABOVE ALL Lighting, Inc. All rights reserved 866-222-8866 info@abovealllighting.com www.AboveAllLighting.com




Notice:

- 1. 72W is default setting.
- 2. Mounting height is 40ft (12m) max. Please check the last page for more sensor setting information.
- 3. Ambient working temperature for Emergency battery backup is 32°F -104°F (0 °C -40°C ).
- 4. Forward throw is standard. Wide throw is optional.
- \* Custom colors are available for an additional fee. Please check with Customer Service for potential lead-times.

# PHOTOMETRY

All published luminaire photo metric testing performed to IESNA LM-79-08 standards by a NVLAP certified laboratory.




# PERFORMANCE DATA

### LUMEN OUTPUT

Lumen values are measured by third party certified laboratories performed in accordance with IESNA LM-79-08 as well as Lighting Facts listed.

Nominal Watts	Tested Watts	Lumen Output	AC Input 120V	ССТ	CRI	LPW
15W	15W	1800	0.13A	4000K	>70	120
30W	30W	3600	0.25A	4000K	>70	120
50W	50W	6000	0.42A	4000K	>70	120
70W	66W	8100	0.60A	4000K	>70	123

## FEATURE




866-222-8866 info@abovealllighting.com www.AboveAllLighting.com



# PIR DIMMING SENSOR FUNCTION

The sensor is an innovative motion sensor, switch on the light on detection of movement, and switch off after a hold time when there is no motion detected.



- 1. No motion detected, all lamps switch off.
- 2. Any movement is detected from any direction, all lampssynchronously switch on.
- 3. No motion is detected in detection area, all lamps synchronously dim to a low light level after hold time.
- 4. After stand-by period, the lamps switch off if no movement is detected in the detection zone.

Note: if you choose STAND-BY DIM is 0, the stand-by period is 0, it is ON/OFF function.

# PIR DIMMING SENSOR SETTING BRI810-B-M8 (120-277V)

By selecting the combination on the DIP switch, sensor data can be precisely set for each specific application. The sensor setting also can be done by a remote control (RC-100) which need to be bought separately.

	1	2	
	↓ ↓	↓ ↓	20%
	↓ ·	1	50%
III	1	↓ ↓	75%
IV	1	1	100%

	3	4	
Ι	+	↓ I	10 S
	Ŧ	1	1 Min
III	1	ŧ	5 Min
IV	Ť	<b>↑</b>	15 Min

	5	6	
	↓ ↓	ŧ	*
	↓ ↓	1	10 Lux
=	1	↓ ↓	30 Lux
IV	1	Ť	50 Lux

	7	8	
I	₽	Ŧ	0%
	<b>↓</b>	1	10%
III	Ť	Ŧ	30%
IV	1	1	50%

	9	10	
Ι	↓ ↓	Ŧ	+ 8
П	↓ ↓	Ť	1 Min
=	1	↓ ↓	30 Min
IV	1	1	60 Min

## WARRANTY

Five year limited warranty.

#### Note: Specifications subject to change without notice.

866-222-8866 info@abovealllighting.com www.AboveAllLighting.com

#### Hold time Refers to the time period the lamp remains at 100% illumination after no motion detected.

Sensitivity can be reduced by selecting the combination on the DIP switches to fit

**Default Setting: 1min** 

precisely each application . Default Setting: 100%

### Daylight sensor

Sensitivity

The sensor can be set to only allow the lamp to illuminate below a defined ambient brightness threshold.

**Default Setting: 30lux** 

### Stand-by dimming level

The low light level you would like to have after the hold time in the long absence of people.

**Default Setting: 30%** 

### Stand-by time

Refers to the time period the lamp remains at a low light level before it completely switches off in the long absence of people. When set to" + $\infty$ " mode, the low light is maintained until motion is detected

Default Setting: +∞